



LISTING INFORMATION OF
**BAN FOUR DWC-LLC - DANSNBAN - 1-hour Single Swing
Wooden Composite Door**
SPEC ID: 55941

BAN FOUR DWC-LLC
P. O. Box 263127
Building A3, Business Center
Dubai World Central, Dubai
United Arab Emirates

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

LISTING INFORMATION

FIRE RESISTANT PRODUCTS & COMPONENTS

CATEGORY B DOORS – ADDITIONAL EDGE-SEALING SYSTEM REQUIRED

PRODUCT COVERED

DANSNBAN 1 hour Single Swing Wooden Composite Door

Model: DANSNBAN FR60UL

Door Size (single swing):

Maximum Width: 1100 mm

Maximum Height: 2400 mm

Minimum Thickness: 45 mm

PRODUCT DESCRIPTION

Hardware Limitations: Cylindrical Lock with maximum bucket 2-3/4 in (70mm) and maximum cylindrical bore hole size of 2-1/8 in (54mm).

Configuration - Size

Single Swing - 1100mm wide x 2400mm high x 45mm thick

Standard Pairs - Not allowed.

Double Egress- Not allowed.

For use with BAN FOUR DWC-LLC - DANSNBAN - 1-hour Wooden Composite Frame only.

BAN FOUR DWC-LLC - DANSNBAN - 1-hour Single Swing Wooden Composite Door is fastened to an aerated concrete or masonry wall by steel bar with nail. The maximum clearance between the wall and the frame is 10mm and the clearance is filled with mineral wool clad with quick-setting cement.

FIRE RATINGS

The product noted above has been tested and qualified 1-hour positive pressure fire rated applications per UL 10C, NFPA 252, and 1-hour neutral pressure fire rated applications per CAN/ULC-S104, UL 10B.

Attribute	Value
Certificate Date of Expiry	December 31, 2020
Certificate Date of Initial Registration	March 25, 2020
Certificate Number	WHI20-34568003
Criteria	CAN / ULC S104 (2015)
Criteria	UL 10(c) (2016)
Criteria	UL 10(b) (R2015)
Criteria	NFPA 252 (2017)
CSI Code	08 10 00 Doors and Frames
Fire Resistance	60 Min PP Category B Door

Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	CATEGORY B - DOORS - ADDITIONAL EDGE-SEALING SYSTEM REQUIRED
Spec ID	55941
Swing	Single Swing