



LISTING INFORMATION OF  
**BAN FOUR DWC-LLC - DANSNBAN - 1-hour Single Swing  
Wooden Composite Door Frame**  
SPEC ID: 55943

BAN FOUR DWC-LLC  
P. O. Box 263127  
Building A3, Business Center  
Dubai World Central, Dubai  
United Arab Emirates

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## LISTING INFORMATION

### FIRE RESISTANT PRODUCTS & COMPONENTS

CATEGORY C - PROPRIETARY FRAMES

### PRODUCT COVERED

DANSNBAN 1-hour Single Swing Wooden Composite Door Frame

Model: DANSNBAN FR60UL

For use with BAN FOUR DWC-LLC - DANSNBAN - 1-hour Single Swing Wooden Composite Door only.

### PRODUCT DESCRIPTION

Frame type: Wooden Composite Frame

Type of wall for use with: Aerated concrete wall or Masonry wall

Frame stop: 15.5 mm high at header and jamb edges

Overall Frame Size (Single Swing):

Maximum Width: 1166mm

Maximum Height: 2437mm

Minimum Depth: 120mm

Door Size (Single Swing):

Maximum Width: 1100mm

Maximum Height: 2400mm

Minimum Thickness: 45mm

Standard Pairs - Not allowed

Double Egress - Not allowed

The frame was fastened to an aerated concrete or masonry wall by steel bar with nails. The maximum clearance between the wall and the frame is 10mm and the clearance is filled with mineral wool clad with quick-setting cement.

### FIRE RATINGS

BAN FOUR DWC-LLC - DANSNBAN - 1-hour Single Swing Wooden Composite Door Frame for use in 1-hour positive pressure fire rated applications per UL 10C, NFPA 252, and 1-hour neutral pressure fire rated applications per CAN/ULC-S104, UL 10B.

Attribute	Value
Certificate Date of Expiry	December 31, 2020
Certificate Date of Initial Registration	March 25, 2020
Certificate Number	WHI20-34568004

Criteria	CAN / ULC S104 (2015)
Criteria	UL 10(c) (2016)
Criteria	UL 10(b) (R2015)
Criteria	NFPA 252 (2017)
CSI Code	08 10 00 Doors and Frames
Fire Resistance	60 Min PP Category C Proprietary Frame
Intertek Services	Certification
Listed or Inspected	LISTED
Listing Section	CATEGORY C - PROPRIETARY FRAMES
Spec ID	55943
Swing	Single Swing